

NATIONAL CERTIFIED TESTING LABORATORIES

1464 GEMINI BOULEVARD * ORLANDO, FLORIDA 32837
PHONE (407) 240-1356 * FAX (407) 240-8882

January 14, 2004

Kennedy Skylights
5294 Tower Way
Sanford, FL 32773

Mr. Walls,

On October 21, 2003, tests were conducted by our laboratory on Kennedy Skylights' 24" x 48" skylight Model "SFG4" in accordance with the ASTM E283-91, "Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen."; ASTM E330-90, "Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference."; ASTM E331-93, "Test Method for Water Penetration of Exterior Windows, Curtain Walls and Doors by Uniform Static Air Pressure Difference" test methods. The test results are as follows:

ASTM E283:	0.04 cfm/ft ²		
ASTM E330:	120.0 psf	23.07" H ₂ O	80 Design Pressure
ASTM E331:	12.0 psf	2.3" H ₂ O	80 Design Pressure

If you have any questions or need additional information please feel free to contact me at your convenience.

Sincerely,
NATIONAL CERTIFIED TESTING LABORATORIES

Rick Moffett
RICK MOFFETT
Technician

PROFESSIONALS IN THE SCIENCE OF TESTING